



**Community Development Department
Building & Safety Division**

**Water-Conserving Plumbing Fixtures
Certificate of Compliance by Property Owner**

Owner(s) Name _____ Permit No. _____

Address _____

Signature (Owner or Contractor) _____

**PERMIT CANNOT BE FINALED AND COMPLETED UNTIL THIS CERTIFICATE
HAS BEEN SIGNED AND RETURNED TO THE BUILDING DIVISION**

I / We, the owners of this property, certify under penalty of perjury that non-compliant plumbing fixtures have been replaced and installed by me/us, or the contractor, with water-conserving plumbing fixtures in accordance with Civil Code Sections 1101.1 through 1101.8, the current California Plumbing Code and California Green Building Standards Code, and manufacturer's installation requirements, and that the water-conserving plumbing fixtures comply with the requirements as indicated in the table below.

Upon completing and signing this Certificate, please return/provide to either contact below in order to final your permit.

City of Dublin
Building & Safety Division
100 Civic Plaza, Dublin CA 94568

OR

Building Inspector
prior to the final inspection

THIS CODE SECTION ONLY AFFECTS BUILDINGS CONSTRUCTED PRIOR TO JANUARY 1, 1994

Fixture Type	Non-Compliant Plumbing Fixture ¹ Water Usage / Flow Rate	Water-Conserving Plumbing Fixture Maximum Water Usage / Flow Rate
		2013 CPC Ch. 4 / 2013 CALGreen Divs. 4.3 and 5.3
Water Closets (Toilets)	Exceed 1.6 gallons/flush	1.28 gallons/flush
Urinals	Exceed 1.0 gallons/flush	0.5 gallons/flush
Showerheads ²	Exceed 2.5 gallons per minute	2.0 gallons per minute @ 80 psi. Also certified to the performance criteria of U.S. EPA WaterSense Specification for Showerheads. (A hand-held shower is considered a showerhead.) For multiple showerheads serving one shower, the combined flow rate of all showerheads and/or other shower outlets controlled by a single valve shall not exceed 2.0 gallons per minute @ 80 psi, or the shower shall be designed to allow only one shower outlet to be in operation at a time.
Lavatory Faucets	Exceed 2.2 gallons per minute	Maximum 1.5 gallons per minute @ 60 psi; minimum 0.8 gallons per minute @ 20 psi In common and public use areas: 0.5 gallons per minute @ 60 psi
Kitchen Faucets ³	Exceed 2.2 gallons per minute	1.8 gallons per minute @ 60 psi May temporarily increase up to 2.2 gallons per minute @ 60 psi, and must default to maximum 1.8 gallons per minute @ 60 psi

1. If the existing plumbing fixture water usage/flow rate is equal to or lower than the figure shown, it is **not** required to be upgraded.

2. Showerheads must be certified to the performance criteria of the U.S. EPA Water Sense Specification for Showerheads.

3. Where complying faucets are unavailable, aerators or other means may be used to achieve reduction.

On and after January 1, 2014, building alterations or improvements shall require all non-compliant plumbing fixtures to be replaced with water-conserving plumbing fixtures throughout the building.

On or before January 1, 2017, all non-compliant plumbing fixtures shall be replaced with water-conserving plumbing fixtures (regardless of whether building undergoes alterations or improvements).